

41

Certificate of Pucca Building and Life span

It is certified that Bhai Nand Lal Public School, Via Mataur, Anandpur Sahib is managed by S.G.P.C is a Pucca Building type.

The under signed inspected the above said school on 20-01-2011 and verified the covered area of the school which is 11000 Sft +14500 Sft = 25500 Sft and the open area is 596970 Sft as per the performa submitted to get building safety certificate, and found it correct.

Type of Construction of School is slab type. Year of Construcation of the Building is One part in 1993-94 and second part in 1999-2000.

Building is built in two types. Partially load bearing and the other part is in R.C.C frame structured.

Keeping in view the type of structure, the life span of the building is about 75 years.

Davinder Kumar

Sub Divisional Engineer
Provl. Sub Division
~~Sub Divisional Engineer~~
Provl. Sub Divn PWD B&E
Anandpur Sahib
Bt Anand Pur Sahib

Asm